



NOTES:

1. (\*) : 15" MAX. FOR PIPE DIAMETER LESS THAN 24", AND 24" MAX. FOR PIPE DIAMETER 24" AND OVER. FOR CONCRETE ARCH, THE MIN. WIDTH SHALL BE EQUAL TO OUTSIDE DIAMETER OF PIPE.
2. "D" REFERS TO THE DIAMETER OF THE PIPE.
3. "T" REFERS TO THE THICKNESS OF THE PIPE.
4. THE NEED FOR CONCRETE ARCH HALF ENCASUREMENT OR FULL ENCASUREMENT TO BE DETERMINED IN THE FIELD AS DIRECTED BY THE CITY.
5. REFER TO SECTION 32.5 OF THE UTILITIES MANUAL FOR SHEETING AND BRACING EXCAVATIONS.
6. ENDS OF ENCASEMENT SHALL BE FORMED, AND LOCATIONS SHALL BE INDICATED ON RECORD DRAWINGS.

CONCRETE ARCH AND ENCASUREMENT DETAILS