



NOTES:

1. IF VALVE BOX RISER IS REQUIRED, USE PVC C900 PIPE EXTENSION AND NOTCH RISER FOR TRACER WIRE.
2. THE ACTUATING NUT FOR DEEPER VALVES SHALL BE EXTENDED TO WITHIN 4 FOOT DEPTH BELOW FINISHED GRADE.
3. CONTRACTOR SHALL PROVIDE THE CITY WITH VALVE KEYS IN ACCORDANCE WITH SECTION 52.4 OF THE UTILITIES MANUAL.

GATE VALVE AND BOX DETAIL