



NOTES:

1. FIRE HYDRANT SHALL BE SUPPLIED WITHOUT A WEEP HOLE, OR WITH A PERMANENTLY PLUGGED WEEP HOLE.
2. THE DEVELOPER SHALL INSTALL THE SHEAR PAD RECESSED 6 INCHES BELOW THE FINISHED GRADE AND SOD THE RECESSED SECTION.
3. CLEARANCE BETWEEN BOTTOM OF BOLTS AND TOP OF SHEAR PAD SHALL BE A 12 INCH MINIMUM.
4. FIRE HYDRANTS SHALL BE MUELLER A-423, AMERICAN DARLING B-84, KENNEDY K81A OR CLOW MEDALLION F-2545.
5. FIRE HYDRANTS SHALL BE IDENTIFIED IN ACCORDANCE WITH SECTION 52.7.5 OF THE UTILITIES MANUAL.
6. CONTRACTOR SHALL PROVIDE THE THE CITY WITH HYDRANT WRENCHES AND VALVE KEYS IN ACCORDANCE WITH SECTIONS 52.4 AND 52.7.3 OF THE UTILITIES MANUAL.

FIRE HYDRANT ASSEMBLY DETAIL