



2 INCH AND BELOW ASSEMBLY

NOTES:

1. ALL PIPE FITTINGS, MATERIALS, LABOR, AND APPURTENANCES SHALL BE SUPPLIED BY THE CONTRACTOR.
2. ALL PIPE AND FITTINGS TWO (2) INCHES AND SMALLER SHALL BE THREADED SCHEDULE 40 GALVANIZED STEEL OR BRASS. (FIGURE 500A).
3. ALL PIPE AND FITTINGS THREE (3) INCHES AND LARGER SHALL BE RESTRAINED JOINT DUCTILE IRON PIPE. ABOVE GRADE JOINTS SHALL BE FACTORY-FLANGED. (FIGURE 500B).
4. VALVES SHALL BE CHAINED CLOSED.(FIGURE 500B)
5. ALL FIRE LINES SHALL BE AS APPROVED BY THE FIRE DEPT. (FIGURE 500B).
6. THE ENTIRE ASSEMBLY SHALL BE PAINTED SAFETY RED FOR FIRE PROTECTION USES AND BLACK FOR ALL OTHER USES.
7. A GATE VALVE SHALL BE INSTALLED AT THE ASSEMBLY'S CONNECTION POINT TO THE MAIN. (FIGURE 500B)

DOUBLE CHECK OR REDUCED PRESSURE ZONE DETECTOR ASSEMBLY

CITY OF SANFORD

1999

FIG. 500A