



SCHEDULE 40 GALVANIZED PIPE AND FITTINGS OR SCHEDULE 80 PVC PIPE AND FITTINGS

METER BOX AND LID TO BE FLUSH WITH FINISHED GRADE.

DOUBLE CHECK PRESSURE OR REDUCED PRESSURE DEVICE

12" TO 30" ABOVE GRADE

FINISHED GRADE

4" TO 6"

WATER MAIN  
 DOUBLE STRAP SADDLE  
 CORP. STOP  
 SERVICE LINE  
 CURB STOP  
 METER

NOTES:

1. A POSITIVE DIELECTRIC CONNECTION SHALL BE MADE BETWEEN ALL GALVANIZED AND BRASS COMPONENTS.
2. METER SHALL BE INSTALLED BETWEEN SIDEWALK AND CURB WHERE APPLICABLE, OR AT PROPERTY LINE AND IN NO CASE SHALL IT BE INSTALLED IN SIDEWALK OR OTHER PAVED AREAS.
3. USE PRIMER SUITED TO BASE MATERIALS. FINISH WITH TWO COATS OF BLACK EXTERIOR ENAMEL.

DOMESTIC METER AND DOUBLE CHECK VALVE OR REDUCED PRESSURE ZONE ASSEMBLY